

**DEPARTMENT OF TRANSPORTATION -Toll Bridge Program**

333 Burma Rd.  
Oakland, CA 94607  
(510) 622-5660, (510) 286-0550 fax



*Flex your power  
Be energy efficient!*

August 30, 2010

Contract No. 04-0120F4  
04-SF-80-13.2 / 13.9  
Self-Anchored Suspension Bridge  
Letter No. 05.03.01-008147

Michael Flowers  
Project Executive  
American Bridge/Fluor, A JV  
375 Burma Road  
Oakland, CA 94607

Dear Michael Flowers,

**Submittal 355, Rev. 5 - Update 1 - Tower: Saddle Grillage Fabrication Procedure**

Please accept this letter as an update to State Letter 05.03.01-007858 issued August 3, 2009, in response to Submittal ABF-SUB-000355R05, "Tower - Saddle Grillage Fabrication Procedure," dated July 22, 2010. The status of the submittal remains "Approved."

The Department's previous Category "A" comment related to Revision 4 of this submittal has been retracted.

**CATEGORY C:**

1. **Sheets FP-MUF-19 and FP-MUF-26:** Based upon WDC discussions at ZPMC, it is understood that there will be a section of the Dimensional Verification Plan describing the grillage and that it will address checks prior to machining.

If you have questions, please contact Mark Woods at (510) 622-5107

Sincerely,

A handwritten signature in blue ink, appearing to read "Rick Morrow".

RICK MORROW  
Construction Manager (Tower)

For: GARY PURSELL  
Resident Engineer

cc: Mark Woods  
file: 05.03.01, 55.0355